



**Notice of Sanitary Sewer Overflow
on December 24, 2022**

At approximately 3:00 PM today, December 24, 2022, the Shrewsbury Water and Sewer Division was alerted to a sanitary sewer overflow in the vicinity of First Avenue and Lake Quinsigamond. Crews responded and quickly identified a power issue with the Harvey Place Sewer Station. They were able to get the station back into operation within 30 of arriving on scene.